## SIEMENS

## **Product data sheet**

## 3RT1015-1BB41



CONTACTOR, AC-3 3 KW/400 V, 1 NO, DC 24 V, 3-POLE, SIZE S00, SCREW CONNECTION

General details:		
product brand name		SIRIUS
product designation		power contactor
Size of the contactor		S00
Protection class IP / on the front		IP20
Degree of pollution		3
Installation altitude / at a height over sea level / maximum	m	2,000
Ambient temperature / during operating	°C	-25 +60
Active power loss / per conductor / typical	W	0.42
Item designation		
according to DIN EN 61346-2		Q
<ul> <li>according to DIN 40719 extendable after IEC 204-2 / according to IEC 750</li> </ul>		К
Mechanical operating cycles as operating time	_	
• of the contactor / typical		30,000,000
<ul> <li>of the contactor with added auxiliary switch block / typical</li> </ul>		10,000,000
<ul> <li>of the contactor with added electronics-compatible auxiliary switch block / typical</li> </ul>		5,000,000
Main circuit:		
Number of poles / for main current circuit		3

Number of NC contacts / for main contacts		0
Number of NO contacts / for main contacts		3
Operating current / at AC-1 / at 400 V / at 40 °C ambient temperature / rated value	A	18
Operating current / at AC-1 / at 400 V / at 60 °C ambient temperature / rated value	A	16
Operating current		
• at AC-3 / at 400 V / rated value	А	7
with 1 current path		
• at DC-1		
• at 24 V / rated value	A	15
• at 110 V / rated value	А	1.5
• at DC-3 / at DC-5		
• at 24 V / rated value	А	15
• at 110 V / rated value	А	0.1
• with 2 current paths in series		
• at DC-1		
• at 24 V / rated value	А	15
• at 110 V / rated value	А	8.4
• at DC-3 / at DC-5		
• at 24 V / rated value	А	15
• at 110 V / rated value	А	0.25
with 3 current paths in series		
• at DC-1		
• at 24 V / rated value	А	15
• at 110 V / rated value	А	15
• at DC-3 / at DC-5		
• at 24 V / rated value	А	15
• at 110 V / rated value	А	15
Service power		
• at AC-1 / at 400 V / rated value	kW	11
• at AC-2 / at 400 V / rated value	kW	3
• at AC-3		
• at 400 V / rated value	kW	3
• at 500 V / rated value	kW	3.5
• at 690 V / rated value	kW	4
Control circuit:		

Control circuit:			
Design of activation		conventional	
Type of voltage / of the controlled supply voltage		DC	
Control supply voltage / 1			

## for DC

rated value

V	24

Auxiliary circuit:				
Contact reliability / of the auxiliary contacts		1 faulty switching per 100 million (17 V, 1 mA)		
Number of NC contacts / for auxiliary contacts	-			
<ul> <li>instantaneous switching</li> </ul>		0		
lagging switching		0		
Number of NO contacts / for auxiliary contacts				
<ul> <li>instantaneous switching</li> </ul>		1		
leading switching		0		
Operating current / of the auxiliary contacts				
• at AC-12 / maximum	А	10		
• at AC-15				
• at 230 V	А	6		
• at 400 V	А	3		
• at DC-12				
• at 60 V	А	6		
• at 110 V	А	3		
• at 220 V	А	1		
• at DC-13				
• at 24 V	А	10		
• at 60 V	А	2		
• at 110 V	А	1		
• at 220 V	А	0.3		

Short-circuit:			
	Shor	t-circ	
		1-011 C	uit.

Design of the fuse link				
• for short-circuit protection of the auxiliary switch / required		fuse gL/gG: 10 A		
<ul> <li>for short-circuit protection of the main circuit</li> </ul>				
<ul> <li>with type of assignment 1 / required</li> </ul>		fuse gL/gG: 35 A		
at type of coordination 2 / required		fuse gL/gG: 20 A		
Installation/mounting/dimensions:				
Type of mounting		screw and snap-on mounting onto 35 mm standard mounting rail according to DIN EN 50022		
series installation		Yes		
Width	mm	45		
Height	mm	57.5		

Distance, to be maintained, to earthed part / sidewards

Depth

mm


mm


72

6

Design of the electrical connection <ul> <li>for main current circuit</li> <li>for auxiliary and control current circuit</li> </ul> <li>Identification number and letter for s <ul> <li>Certificates/approvals:</li> </ul> </li> <li>General Product Approval</li>			screw-type terminals screw-type terminals	
• for auxiliary and control current circ Identification number and letter for s Certificates/approvals:		_	screw-type terminals	
Identification number and letter for s Certificates/approvals:				
Certificates/approvals:	witching elements			
			10 E	
General Product Approval				
cqc CSA	<u>KETI</u>	<u>ROSTEST</u>		
Test Certificates				
Manufacturer other				
Shipping Approval				
ABS BUREAU VERITAS	CONV DNV	GL GL	Lloyd's Register	PRS
Shipping Approval	other			
	Manufacturer	<u>other</u>		
Further information:				
Information- and Downloadcenter (Cahttp://www.siemens.com/industrial-cont				
Industry Mall (Online ordering system http://www.siemens.com/industrial-cont	•			
CAx-Online-Generator http://www.siemens.com/cax				
Service&Support (Manuals, Certificat http://support.automation.siemens.com/		-		

 $\underline{http://www.automation.siemens.com/bilddb/cax\_en.aspx?mlfb=3RT1015-1BB41}$ 





last change:

Feb 10, 2012